



NOTE: The valve should be the high point, water should drain back to the pump tank and to GeoMat to prevent freezing.

| EQUALIZATION/THROTTLE VALVE                         |           |          |                        |
|---|-----------|----------|------------------------|
| Geomatrix Systems, LLC.,                            |           |          |                        |
| 114 Mill Rock Road E. Old Saybrook, CT 060-510-0730 |           |          |                        |
| SCALE   | NONE      | REV.     | 8/15/16                |
| DATE  | 1/31/2010 | ACAD NO. | EQUALIZATION VALVE.DWG |
| DRAWN BY:   | ERP       | SHEET    | 1 OF 1                 |